

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**


No. 507

Dated: 14/02/2024

It is certified that an inspection team headed by **MR. AFZAL AMANULLAH EXECUTIVE ENGINEER** (Name of Officers with designation) from **P.H.E.D. SHAHDOL MP PHED** inspected the **Bellwether International School Shahdol, Gram Vicharpur, Tehsil- Sohagpur, Dist.- Shahdol, (M.P)** on **14/02/2024** and on the basis of Water Test Report (Attached) bearing no. **1011** dated **07/02/2024** of **DISTRICT WATER LABORATORY, PHED, SHAHDOL, MP (PHED Lab)** certified that the **Bellwether International School Shahdol, Gram Vicharpur, Tehsil- Sohagpur, Dist.- Shahdol, (M.P)** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribe by the Central/ State/ U.T. Govt.

This certificate is valid till **13/02/2025**

Signature with seal:


Executive Engineer,
Public Health Engg Division
Shahdol (M.P.)

Name:

MR. AFZAL AMANULLAH

Designation:

EXECUTIVE ENGINEERName & address of the office/Department: - **P.H.E. Division Shahdol (M.P.)**

To,

Bellwether International School Shahdol,
Gram Vicharpur, Tehsil- Sohagpur, Dist.- Shahdol, (M.P)
(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies


PRINCIPAL
BELLWETHER INTERNATIONAL
SCHOOL, SHAHDOL (M.P.)


President
RAJ Education and Sports Academy

DISTRICT WATER TESTING LABORATORY

Public Health Engineering Deptt. Shahdol

DISTRICT Shahdol

BLOCK Sahagpur

VILLAGE

<u>Vichaspur</u>

Code No

Code No

To, Principal.

Bell weather International

Particular of Sample School, Shahdol M.P. SA. No. & Details of Source & Location

- (1) Date of Collection 06.2.2024 (i)
- (2) Date of Analysis 07.2.2024 (ii) 1011 - Tube well inside
 (iii) School campus.
 (iv)

Table - 2.2 BIS Standard : Is - 10500-1991

S. No.	Characteristics	Unit	Require Desirable Limit	Permissible limit in the absence of alternative source	Result	Sample No.
PHYSICAL TEST						1011
1.	Turbidity	N.T.U.	5	10	0.5	
2.	Colour	Hazen Units	5.0	25	0	
3.	Taste	-	Agreeable	-	Agreeable	
4.	Odour	-	Unobjectionable	-	Unobjectionable	
CHEMICAL TEST						
4.	PH	PH Scale	7.0 To 8.5	No relaxation	6.7	
5.	Conductivity	Micro Mhos/cm	-	-	147	
6.	Total Alkalinity	mg/l	200	600	100	
7.	Chlorides (As Cl)	mg/l	250	1000	35	
8.	Nitrates (As NO ₃)	mg/l	45	45	0	
9.	Total Hardness (As CaCo ₃)	mg/l	300	600	120	
10.	Total Dissolved Solids	mg/l	500	2000	115	
11.	Iron (As Fee)	mg/l	0.3	1.00	0.3	
12.	Fluorides (As F)	mg/l	1.00	1.5	0	
13.	Sulphates (As SO ₄)	mg/l	200	400	28	
14.	Residual Chlorine	mg/l	0.2	-	0	
BACTERIOLOGICAL TEST						
15.	Coliform Organisms at 37°C	M.P.N./100ml.	-	-	NIL	

TESTED BY - Vinita Bajpai

REMARKS -

[Signature]
 Chemist
 Name & Signature
 Of Lab In Charge

[Signature]
 PRINCIPAL
 BELLWEATHER INTERNATIONAL
 SCHOOL, SHAHDOL (M.P.)

[Signature]
 President
 MAJ Education and Sports Academy