

PERFORMA SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 520

Date: 15/07/2026

It is certified that an inspection team headed by Vivek Tiwari

Assistant Engineer (Name of Officers with designation) from SHAHDOL PHED inspected the **BELLWETHER INTERNATIONAL SCHOOL, SHAHDOL (M.P.)**, Village VICHARPUR, PANCHGAON ROAD, SHAHDOL (M.P.) on 08/06/2026 and on the basis of water testing report (Attached) bearing no 69 dated 09/06/2026 of District water Testing (PHED Lab.) certified that the **BELLWETHER INTERNATIONAL SCHOOL, SHAHDOL (M.P.)** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T. Govt.

The above valid till 1 year

Signature with Seal:

Name: H.E. Sub Division Shahdol
Dist. Shahdol (M.P.)

Designation: Assistant Engineer

Name & address of the officer/ Department:- P.H.E. Division Shahdol (M.P.)

To,

Bellwether international School, Shahdol
Gram- Vicharpur, Tehsil- Sohagpur, Dist.- Shahdol (M.P.)
(Name and address of the institution)

Note:- The certificate is to be issued by authorised officer/PHED Lab/Local bodies.

SP
DIRECTOR
BELLWETHER INTERNATIONAL
SCHOOL, SHAHDOL (M.P.)

Principal
PRINCIPAL
BELLWETHER INTERNATIONAL
SCHOOL, AFFILIATION NO.1031394

DISTRICT WATER TESTING LABORATORY SHAHDOL (M.P.)**PUBLIC HEALTH ENGINEERING DEPARTMENT (P.H.E.D)****ADDRESS: Opposite PWD Office, Pandavnagar****District- Shahdol (M.P.) Pin code-484001****Email Id: eephedshd@nic.in****Mobile No: 9425164895**

TC-17187

Test Report

Nature of Sample: Drinking Water (T.W.)		TC171872600000031F	
Sender's Name	Principal, Bellwether International School		
Sender's Address	Vicharpur, Shahdol (M.P.)		
Sender's letter date	03/06/2026	Unique Identification No.	260608-SR-101.
Sender's letter no/Receipt No.	58	Sample receiving date	08.06.2026
Report Dispatch no.	69	Start Date of analysis	08.06.2026
Reporting Date	09.06.2026	Date of Analysis Completed	09.06.2026

Sample Details:

S.No	Individual UID No.	Block/Gram panchayat	Village	Particulars of samples	Condition of sample	Quantity of samples
149	260625-SR-101	Kalyanpur	Vicharpur	Tubewell Sammple	Ok	1 Ltr.
				Inside School Campus		

Physical & Chemical Test Report with Details of Parameters, Their Test Methods & Units

S. No	Characteristics	Unit	Test Methods	As per the BIS 10500:2012		Results			
				Desirable limit	Permissible limit	149			
1	pH at 25°C	pH	IS 3025 Part-11	6.5-8.5	No relaxation	7.0			
2	Odor	-	IS:3025 Part 5	Agreeable	Agreeable	Agree			
3	Color	Hazen	IS:3025 Part 4	5	15	0			
4	Taste	-	IS:3025 Part 8	Agreeable	Agreeable	Agree			
5	Total Alkalinity as CaCo3	Mg/l	IS 3025 Part -23	200	600	40			
6	Total Hardness as CaCo3	Mg/l	IS 3025 Part -21	200	600	120			
7	Calcium as Ca++	Mg/l	IS 3025 Part -40	75	200	-			
8	Magnesium as Mg++	Mg/l	IS 3025 Part -46	30	100	-			
9	Chlorides as Cl ⁻	Mg/l	IS 3025 Part -32	250	1000	25			
10	Turbidity	NTU	IS 3025 Part-10	1	5	0.3			
11	Electrical Conductivity at 25°C	μmho/cm	IS 3025 Part -14	-	-	222.3			

49. This report should not be produced partly or full without approval of signatory authority for legal purposes.
50. It is recommended that acceptable limit is to be implemented. No amendment is allowed in the test report. Controlled copy of the report is kept at the lab for any dispute
51. The results refer only to tested sample and parameters tested.
52. Samples will be stored for a period of 10 days from the date of issue of Test report.
53. This lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.
54. Decision Rule: Laboratory does not provide decision rule/Opinion & Interpretation. Kindly go through lower & upper limit as per IS 10500:2012 as given on the test report of concern parameter tested

Reviewed By Authorized Signatory
Technical Manager (Pratima Shukla)-

PRATIMA SHUKLA

Technical Manager

Dist. Water Testing Laboratory

P.H.E. DN SHAHDOL (M.P.)

-----End of Report-----

48 | 1

PRINCIPAL
BELLWETHER INTERNATIONAL
SCHOOL AFFILIATION NO.1031394

DIRECTOR
BELLWETHER INTERNATIONAL
SCHOOL, SHAHDOL (M.P.)

DISTRICT WATER TESTING LABORATORY SHAHDOL (M.P.)

PUBLIC HEALTH ENGINEERING DEPARTMENT (P.H.E.D)
ADDRESS: Opposite PWD Office, Pandavnagar District- Shahdol (M.P.)

Pin code-484001

Test Report

Nature of Sample: Drinking Water (T.W.)

Particular Of Sender: Principal, Bellwether International School Vicharpur, Shahdol (M.P.)

Particular Of Sample: Collected by PHED / Not Collected by PHED

Sample Collection Date	08.06.2026	Sample receiving date	08.06.2026
Date of Analysis	09.06.2026	Reporting Date & Time	09.06.2026

Sample Details:

Sample no.	Block/Gram panchayat	Village	Particulars of samples	Condition of sample	Quantity of samples
149	Kalyanpur	Vicharpur	Tubewell Sammple Inside School Campus	Ok	1 Ltr.

Physical , Chemical and Bacteriological Test Report with Details of Parameters

S. No	Characteristics	Unit	As per the BIS 10500:2012		Results				
			Desirable limit	Permissible limit					
					149				
1	Nitrates (As NO ₃)	mg/l	45	45	0				
2	Total Dissolved Solids	mg/l	500	2000	148.9 2				
3	Iron	mg/l	0.3	1.0	0.1				
4	Sulphate (As SO ₄)	mg/l	200	400	-				
5	Fluorides (As F)	mg/l	1.0	1.5	0.0				
6	Manganese as Mn	mg/l	0.1	0.3	-				
7	Residual Chlorine as Cl ₂	mg/l	0.2	1.0	0.0				
8	Arsenic(as aAs)	mg/l	0.01	0.01	-				
9	Total Coliform	Per 100 ml.	Nil		NIL				
	Faecal Coliform	Per 100 ml.							

Tested By Poojima Shukla & Ramnaresh

[Signature]
Chemist
P.H.E.D. Shahdol

Remark NA

-----End of Report-----

[Signature]
PRINCIPAL
BELLWETHER INTERNATIONAL
SCHOOL, AFFILIATION NO.1031394

[Signature]
DIRECTOR
BELLWETHER INTERNATIONAL
SCHOOL, SHAHDOL (M.P.)